



- NOTES:**
- DESIGN INTENT IS TO INSTALL A NEW SEPARATED SANITARY SEWER MAIN AND LEAVE THE EXISTING COMBINED SEWER IN PLACE AS A STORM DRAIN.
  - DESIGN INTENT IS TO ALIGN NEW BUILDING SEWER SERVICES TO ALLOW EXISTING BUILDING SEWER SERVICE CONNECTED TO THE COMBINED SEWER TO REMAIN AS FUTURE DRAIN STUB.
  - ACCESS NOT GAINED TO RESIDENCE. CONDUCT TEST PIT IN ADVANCE TO DETERMINE LOCATION, ELEVATION, SIZE AND MATERIAL.
  - CONDUCT TEST PIT IN ADVANCE OF ORDERING MH TO VERIFY LOCATION AND ELEVATION OF EXISTING VC COMBINED SEWER AND VERIFY NEW MANHOLE INVERT ELEVATIONS.
  - PROVIDE 2-1/2" THICK TRENCH PAVEMENT AND 1-1/2" THICK FULL ROAD WIDTH PAVEMENT OVERLAY AT COMPLETION OF NEW SEWER INSTALLATION ON BENNETT AVENUE.
  - A NEW 8" DI WATER MAIN AND NEW WATER SERVICES WILL BE INSTALLED BY THE MAINE WATER COMPANY UNDER SEPARATE CONTRACT AND IN ADVANCE OF NEW SEWER IMPROVEMENTS. EXISTING 6" CI WATER MAIN WILL BE ABANDONED.



**OLVER ASSOCIATES INC.**  
 ENVIRONMENTAL ENGINEERS  
 290 MAIN STREET WINTERPORT, MAINE

DATE	ADDITION OR REVISION		
DES. BY: EWH	DR. BY: FLE	CK. BY: MHO	
TOWN OF SKOWHEGAN, MAINE			
CSO ABATEMENT PHASE 3.2			
<b>BENNETT AVENUE SEWER AND STORM DRAIN PLAN &amp; PROFILES</b>			
SCALE: AS NOTED	PROJECT NO.: 1293-2		
DATE: DECEMBER, 2013	SHEET: C-7		