

AUBUCHON
HARDWARE

LEGEND


- R: INDICATES 120V RECEPTACLE AT POLE
- S1: FIXTURE TYPE
- S1-EX: EXISTING LIGHTING FIXTURE (2)
- P2-1,3 LIGHTING CKT (240V)
- P4 CABLE DESIGNATION
1" CONDUIT

CABLE DESIGNATIONS

- P1 - 2#10AWG+#10AWG GND
- P2 - 4#8AWG+2#10AWG GND
- P3 - 2#8AWG + #10AWG GND

NOTES

1. 5" PVC CONDUIT ARRANGED TO DRAIN IN HANDHOLE HH1. DRAIN HH1 BY CREATING WEEP HOLES IN THE BOTTOM OF THE BOX.
2. SEE DETAIL 2, DRAWING E-2 FOR POLE FOUNDATION.
3. SEE DETAIL 1, DRAWING E-2 FOR DUCT BANK.
4. SEE CIVIL AND LANDSCAPE DRAWING FOR ADDITIONAL INFORMATION.
5. SEE DRAWING E-2 FOR FIXTURE SCHEDULE.



Note: On the Original Full-Scale Drawing, this dimension is 6"

NO.		REVISIONS		DATE	TOWN OF SKOWHEGAN SKOWHEGAN, MAINE	
SCALE:		AS NOTED		DATE:	MUNICIPAL PARKING LOT PEDESTRIAN CONNECTOR PROJECT	
DRAWN BY:		CAT		CHECKED:	MLC	
APPROVED:				PROJECT:	3223	
FIELD BK:						SHEET 7 of 8 E-1
FILE:				DIRIGO ENGINEERING 2 DIRIGO DRIVE, FAIRFIELD, MAINE 04937 (207) 453-2401		

